

	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02	
		Rev No: 6	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 190 - 466.0

Issue Date: 4/2/2008

Revision Date: 11/27/2013

Expiration Date: 1/10/2016

Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review of the product qualification documents for the product named below. This report is only valid when signed by an officer of KCI, and indicates the product as manufactured by the company named below has been tested and meets the requirements of the referenced standard and is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Model: HR-210/201 Aluminum Horizontal Slider XO Operator Type: HS Config: NO Max Width: 74 Max Height: 72

Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/IS2/A440-05	HS-R45 1880x1829 (74x72)

Qualifying Test Information:	
Test Report No:	ATI-78026.01-401-47
Test Report Expiration:	1/10/2016

Authorized Signature:



Digitally signed by Steven M. Ulrich
DN: cn=Steven M. Ulrich,
o=Keystone Certifications, Inc., ou,
email=surich@keystonecerts.com,
c=US
Date: 2013.11.27 13:34:19 -05'00'

Keystone Certifications, Inc.

564 Old York Road, Suite 5
Etters, Pennsylvania 17319
Phone: 717-932-8500
Fax: 717-932-8501