	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02	
		Rev No: 7	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 190 - 478.0
Issue Date: 2/25/2009
Revision Date: 11/21/2014
Expiration Date: 2/16/2019
Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Model: SH200 (SH4001) Aluminum Oriel Single Hung Operator Type: H Config: No Max Width: 52 Max Height: 75

Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/IS2/A440-05	H-LC55 1321x1905 (52x75)

Qualifying Test Information:	
Test Report No:	ATI-89077.01-401-47
Test Report Expiration:	2/16/2019


Authorized Signature:



Digitally signed by Jon
Hill
Date: 2014.11.24
11:02:13 -05'00'

Keystone Certifications, Inc.

564 Old York Road, Suite 5
Etters, Pennsylvania 17319
Phone: 717-932-8500
Fax: 717-932-8501

	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02	
		Rev No: 7	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 190 - 479.0
Issue Date: 2/25/2009
Revision Date: 11/21/2014
Expiration Date: 2/16/2019
Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Model: SH200 (SH4001) Aluminum Equal Single Hung Operator Type: H Config: No Max Width: 52 Max Height: 75

Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/IS2/A440-05	H-LC55 1321x1905 (52x75)

Qualifying Test Information:	
Test Report No:	ATI-89077.01-401-47
Test Report Expiration:	2/16/2019


Authorized Signature:



Digitally signed by Jon
Hill
Date: 2014.11.24
11:01:31 -05'00'

Keystone Certifications, Inc.

564 Old York Road, Suite 5
Etters, Pennsylvania 17319
Phone: 717-932-8500
Fax: 717-932-8501

	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02		
		Rev No: 7	Page: 1	Of: 1
Required By: PRO B1-03				

CAR & Product ID Number: 190 - 493.0

Issue Date: 3/30/2009

Revision Date: 11/21/2014

Expiration Date: 3/16/2019

Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Model: SH200 (SH4000) Oriel Aluminum Single Hung Operator Type: H Config: No Max Width: 53 Max Height: 76

Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/IS2/A440-05	H-LC55 1346x1930 (53x76)

Qualifying Test Information:	
Test Report No:	ATI-89765.01-401-47
Test Report Expiration:	3/16/2019


Authorized Signature:



Digitally signed by Jon Hill
Date: 2014.11.24
10:57:26 -05'00'

Keystone Certifications, Inc.

564 Old York Road, Suite 5
Etters, Pennsylvania 17319
Phone: 717-932-8500
Fax: 717-932-8501

	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02		
		Rev No: 7	Page: 1	Of: 1
Required By: PRO B1-03				

CAR & Product ID Number: 190 - 494.0
Issue Date: 3/30/2009
Revision Date: 11/21/2014
Expiration Date: 3/16/2019
Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.


This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Model: SH200 (SH4000) Equal Lite Aluminum Single Hung Operator Type: H Config: No Max Width: 53 Max Height: 76


Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/IS2/A440-05	H-LC55 1346x1930 (53x76)

Qualifying Test Information:	
Test Report No:	ATI-89765.01-401-47
Test Report Expiration:	3/16/2019

Authorized Signature:


Digitally signed by Jon Hill
Date: 2014.11.24 10:56:38 -05'00'

Keystone Certifications, Inc.
564 Old York Road, Suite 5
Etters, Pennsylvania 17319
Phone: 717-932-8500
Fax: 717-932-8501

	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02		
		Rev No: 6	Page: 1 Of: 1	
Required By: PRO B1-03				

CAR & Product ID Number: 190 - 1002
Issue Date: 08/14/2012
Revision Date: 08/14/2012
Expiration Date: 05/28/2016
Licensee Code: 190


This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review of the product specification documents for the product named below. This report is only valid when signed by an officer of KCI, and indicates the product as manufactured by the company named below has been tested and meets the requirements of the referenced standard and is eligible for the application of Keystone Certification Program certification labels. The licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis, FL 34274	Model Name: SH200 (SH 4000) Single Hung Pass-Thru Window Operator Type: H Configuration: No Max. Width: 53 Max. Height: 52

Referenced Standard:	Product Rating:
ASTM:E283-04/E330-02, AAMA 1302.5-76	E283:0.06cfm/ft,E330:DP +/-65, 1302.5:Pass Size:53x52

Qualifying Test Information:	
Test Report No:	FTL-6878
Test Report Expiration:	05/28/2016

Authorized Signature:



Keystone Certifications, Inc.
564 Old York Road, Suite 5
Etters, Pennsylvania 17319
Phone: 717-932-8500
Fax: 717-932-8501