

	Document Title:	Doc No:	FRM B1-02	
	Structural Performance Certification Authorization Report	Rev No: 6	Page: 1	Of: 1
Required By: PRO B1-03				

CAR & Product ID Number: 190 - 789.0
Issue Date: 10/20/2011
Revision Date: 10/20/2011
Expiration Date: 9/21/2015
Company Code: 190


This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review of the product qualification documents for the product named below. This report is only valid when signed by an officer of KCI, and indicates the product as manufactured by the company named below has been tested and meets the requirements of the referenced standard and is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Model: CD290 Cabana Full Lite Aluminum Outswing Door Operator Type: SHD Config: No, GS-1/8" Temp Mono Max Width: 37 Max Height: 81

Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG50 949x2051 (37x81)-Type SHD

Qualifying Test Information:	
Test Report No:	FTL-6631/6634
Test Report Expiration:	9/21/2015

Authorized Signature:


Digitally signed by Steven M. Urich
DN: cn=Steven M. Urich,
o=Keystone Certifications, Inc., ou,
email=surich@keystonecerts.com,
c=US
Date: 2011.10.24 08:40:36 -04'00'

Keystone Certifications, Inc.

564 Old York Road, Suite 5
Etters, Pennsylvania 17319
Phone: 717-932-8500
Fax: 717-932-8501