

Document Title:

Impact Performance Certification Authorization Report

| Doc No: | | FRN | I B1- | 43 | |
|---------|---|-------|-------|-----|---|
| Rev No: | 3 | Page: | 1 | Of: | 1 |

Required By: PRO B1-03

CAR & Product ID Number: 190 - 271

Issue Date: 1/23/2012 Revision Date: 1/24/2012 Expiration Date: 11/22/2015

Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review of the product qualification documents for the product named below. This report is only valid when signed by an officer of KCI, and indicates the product as manufactured by the company named below has been tested and meets the requirements of the referenced standard and is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

| Licensee Information: | | | Product Information: |
|--|----|----------------------|--|
| PGT Industries 1070 Technology Dr. Nokomis | FL | PO Box 1529 34274 | Model: CA-540 PVC Fin/Equal Leg Impact Casement Operator Type: C Config: All, GS-5/16" Ann Lami IG Max Width: 36 Max Height: 75 Corresponding Structural CARs: 190-797.1 |

| Referenced Standard: | Product Rating: |
|-----------------------------------|---|
| AAMA 506-08 & ASTM E1886/E1996-05 | Missile Level D, Wind Zone 4, DP +/-60, 36x75 |

| Qualifying Test Information: | | |
|------------------------------|----------------------------|--|
| Test Report No: | FTL-6695,6698-99,6702,6795 | |
| Test Report Expiration: | 11/22/2015 | |

Authorized Signature:

Keystone Certifications, Inc.

564 Old York Road, Suite 5 Etters, Pennsylvania 17319 Phone: 717-932-8500

Fax: 717-932-8501



Document Title:

Structural Performance Certification Authorization Report

| Doc No: | | FRM | 1 B1- | 02 | |
|---------|---|-------|-------|-----|---|
| Rev No: | 6 | Page: | 1 | Of: | 1 |

Required By:

PRO B1-03

CAR & Product ID Number: 190 - 797.1

Issue Date: 1/24/2012
Revision Date: 1/24/2012
Expiration Date: 10/28/2015

Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review of the product qualification documents for the product named below. This report is only valid when signed by an officer of KCI, and indicates the product as manufactured by the company named below has been tested and meets the requirements of the referenced standard and is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

| Licensee Information: | Product Information: |
|---------------------------------|--|
| PGT Industries | Model: CA-440/540 Vinyl Fin/Equal Leg Casement |
| 1070 Technology Dr. PO Box 1529 | Operator Type: C |
| Nokomis FL 34274 | Config: All |
| | Max Width: 36 |
| | Max Height: 75 |

| Referenced Standard: | Product Rating: |
|---------------------------------|----------------------------------|
| AAMA/WDMA/CSA 101/I.S.2/A440-08 | Class LC-PG60 914x1905 (36x75)-C |

| Qualifying Test Information: | | |
|------------------------------|---------------|--|
| Test Report No: | FTL-6692/6694 | |
| Test Report Expiration: | 10/28/2015 | |

Authorized Signature:

Keystone Certifications, Inc.

564 Old York Road, Suite 5 Etters, Pennsylvania 17319 Phone: 717-932-8500

Fax: 717-932-8501