	Document Title:	Doc No: FRM B1-02		
	Structural Performance Certification Authorization Report	Rev No: 6	Page: 1	Of: 1
Required By: PRO B1-03				

CAR & Product ID Number: 190 - 1004.0
 Issue Date: 10/3/2013
 Revision Date: 10/3/2013
 Expiration Date: 5/25/2017
 Company Code: 190


This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review of the product qualification documents for the product named below. This report is only valid when signed by an officer of KCI, and indicates the product as manufactured by the company named below has been tested and meets the requirements of the referenced standard and is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Model: FD455 Transom Operator Type: TR Config: Wide Frame, GS-1/8" Temp IG Max Width: 111 Max Height: 40

Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG70 2819x1016 (111x40)-Type TR

Qualifying Test Information:	
Test Report No:	FTL-7401
Test Report Expiration:	5/25/2017


Authorized Signature:



Digitally signed by Jon Hill
 DN: cn=Jon Hill, o=Keystone
 Certifications, Inc., ou,
 email=jhill@keystonecerts.com,
 c=US
 Date: 2013.10.03 10:32:41 -04'00'

Keystone Certifications, Inc.

564 Old York Road, Suite 5
 Etters, Pennsylvania 17319
 Phone: 717-932-8500
 Fax: 717-932-8501

	Document Title:	Doc No: FRM B1-02		
	Structural Performance Certification Authorization Report	Rev No: 6	Page: 1	Of: 1
Required By: PRO B1-03				

CAR & Product ID Number: 190 - 1005.0
 Issue Date: 10/3/2013
 Revision Date: 10/3/2013
 Expiration Date: 5/25/2017
 Company Code: 190


This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review of the product qualification documents for the product named below. This report is only valid when signed by an officer of KCI, and indicates the product as manufactured by the company named below has been tested and meets the requirements of the referenced standard and is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Model: FD455 Sidelite Operator Type: SLT Config: Wide Frame, GS-1/8" Temp IG Max Width: 40 Max Height: 111

Referenced Standard:	Product Rating:
AAMA WDMA/CSA 101/I.S.2/A440-08	Class R-PG70 1016x2819 (40x111)-Type SLT

Qualifying Test Information:	
Test Report No:	FTL-7401
Test Report Expiration:	5/25/2017


Authorized Signature:



Digitally signed by Jon Hill
 DN: cn=Jon Hill, o=Keystone
 Certifications, Inc., ou,
 email=jhill@keystonecerts.com,
 c=US
 Date: 2013.10.03 10:33:31 -04'00'

Keystone Certifications, Inc.

564 Old York Road, Suite 5
 Etters, Pennsylvania 17319
 Phone: 717-932-8500
 Fax: 717-932-8501

	Document Title:	Doc No:	FRM B1-02	
	Structural Performance Certification Authorization Report	Rev No: 6	Page: 1	Of: 1
Required By: PRO B1-03				

CAR & Product ID Number: 190 - 1008.0
Issue Date: 10/7/2013
Revision Date: 10/7/2013
Expiration Date: 5/21/2017
Company Code: 190


This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review of the product qualification documents for the product named below. This report is only valid when signed by an officer of KCI, and indicates the product as manufactured by the company named below has been tested and meets the requirements of the referenced standard and is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Model: FD455 OS French Door XX Operator Type: SHD Config: All Max Width: 76 Max Height: 96

Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG70 1930x2438 (76x96)-Type SHD

Qualifying Test Information:	
Test Report No:	FTL-7417
Test Report Expiration:	5/21/2017


Authorized Signature:



Digitally signed by Jon Hill
DN: cn=Jon Hill, o=Keystone
Certifications, Inc., ou,
email=jhill@keystonecerts.com,
c=US
Date: 2013.10.07 15:30:58 -04'00'

Keystone Certifications, Inc.

564 Old York Road, Suite 5
Etters, Pennsylvania 17319
Phone: 717-932-8500
Fax: 717-932-8501

	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02	
		Rev No: 6	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 190 - 1010.0
Issue Date: 10/8/2013
Revision Date: 10/8/2013
Expiration Date: 5/21/2017
Company Code: 190


This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review of the product qualification documents for the product named below. This report is only valid when signed by an officer of KCI, and indicates the product as manufactured by the company named below has been tested and meets the requirements of the referenced standard and is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Model: FD455/FD555 Door/Sidelite Mullion Operator Type: Mull Config: Mull Max Width: 124 Max Height: 96

Referenced Standard:	Product Rating:
AAMA 450-10	DP +/-70, Max Size=124x96 Panel width=41"

Qualifying Test Information:	
Test Report No:	FTL-7416
Test Report Expiration:	5/21/2017

Authorized Signature:



Digitally signed by Jon Hill
DN: cn=Jon Hill, o=Keystone
Certifications, Inc., ou,
email=jhill@keystonecerts.com,
c=US
Date: 2013.10.08 17:24:12 -04'00'

Keystone Certifications, Inc.

564 Old York Road, Suite 5
Etters, Pennsylvania 17319
Phone: 717-932-8500
Fax: 717-932-8501