

	Document Title: Impact Performance Certification Authorization Report	Doc No: FRM B1-43		
		Rev No: 3	Page: 1	Of: 1
Required By: PRO B1-03				

CAR & Product ID Number: 190 - 248

Issue Date: 1/26/2010

Revision Date: 12/27/2011

Expiration Date: 5/30/2014

Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review of the product qualification documents for the product named below. This report is only valid when signed by an officer of KCI, and indicates the product as manufactured by the company named below has been tested and meets the requirements of the referenced standard and is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Model: CA2740 Impact Casement Operator Type: C Config: All/Snub, GS-5/16" HS Lami IG or Mono Max Width: 36 Max Height: 76 Corresponding Structural CARs: 190-755.0

Referenced Standard:	Product Rating:
ASTM E1886/E1996-05 & AAMA 506-08	Missile Level D, Wind Zone 4, DP +65/-80, 36x76

Qualifying Test Information:	
Test Report No:	NCTL-210-3634-2A
Test Report Expiration:	5/30/2014

Authorized Signature:



Digitally signed by Steven M. Urich
DN: cn=Steven M. Urich,
o=Keystone Certifications, Inc., ou,
email=surich@keystonecerts.com,
c=US
Date: 2011.12.27 09:35:17 -05'00'

Keystone Certifications, Inc.

564 Old York Road, Suite 5

Etters, Pennsylvania 17319

Phone: 717-932-8500

Fax: 717-932-8501

	Document Title:	Doc No:	FRM B1-02	
	Structural Performance Certification Authorization Report	Rev No: 6	Page: 1	Of: 1
Required By: PRO B1-03				

CAR & Product ID Number: 190 - 755.0
 Issue Date: 1/26/2010
 Revision Date: 12/27/2011
 Expiration Date: 5/30/2014
 Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review of the product qualification documents for the product named below. This report is only valid when signed by an officer of KCI, and indicates the product as manufactured by the company named below has been tested and meets the requirements of the referenced standard and is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Model: CA2740 Impact Casement Operator Type: C Config: All/Snub, GS-5/16" HS Lami IG or Mono Max Width: 36 Max Height: 76

Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/IS2/A440-05	C-C65 914x1930 (36x76) Neg DP=80

Qualifying Test Information:	
Test Report No:	NCTL-210-3634-2A
Test Report Expiration:	5/30/2014

Authorized Signature:



Digitally signed by Steven M. Urich
 DN: cn=Steven M. Urich,
 o=Keystone Certifications, Inc., ou,
 email=surich@keystonecerts.com,
 c=US
 Date: 2011.12.27 09:34:18 -05'00'

Keystone Certifications, Inc.

564 Old York Road, Suite 5
 Etters, Pennsylvania 17319
 Phone: 717-932-8500
 Fax: 717-932-8501